

Nombre de archivo: /tmp/pendrive//tfg7-bal.srbain

Impreso en: 19.12.2020 10:08:26

Medido en: 19.12.2020 09:51:47

Tarea: user intermediate Ajuste de medición: user balancing

Ajuste del sensor: VIB 6.147

Pasos para balanceo

No.	Masa [g]	Angulo [°]	Vibration Ef. [mm/s]	Angulo [°]	Revolución [1/min]
0 A+	---	---	0.769	72	930
0 B	---	---	4.691	165	930
1 A+	3.7	225	0.676	81	928
1 B	---	---	4.088	172	928
2 A+	18.3	273	0.425	315	928
2 B	---	---	0.173	351	928
3 A+	1.6	135	0.330	293	928
3 B	---	---	0.253	235	928
* 4 A+	1.0	75	0.401	300	928
4 B	---	---	0.485	183	928
5 A+	0.7	75	---	---	---
5 B	---	---	---	---	---

Info de máquina

Nombre máquina: user intermediate

Calidad Meta de balanceo: 6.30

Calidad actual de balanceo: 29.64 @ 900 1/min