

Nombre de archivo: tfg-3balan---radio.srbain

Impreso en: 12.12.2020 13:46:29

Medido en: 05.12.2020 14:19:19

Tarea: user intermediate Ajuste de medición: user balancing

Ajuste del sensor: VIB 6.147

Pasos para balanceo

No.	Masa [g]	Angulo [°]	Vibration Ef. [mm/s]	Angulo [°]	Revolución [1/min]
0 A+	---	---	0.743	6	931
0 B	---	---	4.842	180	931
* 1 A+	3.8	150	0.947	9	930
1 B	---	---	5.462	189	930
2 A+	16.9	273	0.357	45	930
2 B	---	---	1.950	224	930
3 A+	4.9	315	0.238	71	930
3 B	---	---	0.798	239	930
4 A+	1.9	345	0.206	96	930
4 B	---	---	0.243	236	930
5 A+	0.6	16	---	---	---
5 B	---	---	---	---	---

Info de máquina

Nombre máquina: user intermediate

Calidad Meta de balanceo: 6.30

Calidad actual de balanceo: 14.61 @ 900 1/min